

	Montaj analizor oxigen CO,CO2 iesire gaze arse Instalatia CC Jurnal de cabluri	08.03.2017	Nastasi D.	Dimitriu Maria Ana
			Data/ Date	Intocmit/ Designer	Verificat/ Checked
			Pag/Pag. __ 1 __ din/from __ 2 __		

Jurnal de cabluri

04				
03				
02				
01				
00	Emis pentru construire	08.03.2017	Nastasi D.	Dimitriu Maria Ana
Rev/Rev.	Denumirea modificarii/Change description	Data/Date	Intocmit/Designer	Verificat/Checked
S.C. OPTIMATIC SOLUTIONS S.R.L. www.optimaticsolutions.ro office@optimaticsolutions.ro ROMANIA, Ploiesti, Bobalna street, no 62B		S.C. PETROTEL LUKOIL S.A. ROMANIA, Ploiesti, Str. Mihai Bravu, nr.235		
		Nr.contract/ Contract no.	Nr. desen/Drawing no.	Rev/Rev
		1637.3./2017	1637.3-A-0008.17	0
Beneficiar/Customer : SC PETROTEL – LUKOIL S.A			Specialitate doc/Specialty doc.	F
Instalatia/Plant : CC			AUTOMATIZARI	A4
Scara/Scale	Denumire document/Document name			
-	Jurnal de cabluri			

		Montaj analizor oxigen CO,CO2 iesire gaze arse Instalatia CC Jurnal de cabluri	08.03.2017	Nastasi D.	Dimitriu Maria Ana
			Data/ Date	Intocmit/ Designer	Verificat/ Checked
			Pag/Pag. __ 2 __ din/from __ 2 __		

Jurnal Cabluri

Eticheta	De la	La	Tip	Lungime cablu [m]
C-09F-JB01-1	09F-JB01	09F –JB-1000	1	10
C-09F-JB01-2	09F-JB01	09F –JB-1000	1	10
C-09F-JB01-3	09F-JB01	09F –JB-1000	1	10
C-09F-JB01-4	09F-JB01	Dulap Marshaling CC	1	230

JB01 reprezinta cutia de jonctiune montata pe analizorul 09F-AI-O2

Nota : Cablurile se vor taia la lungime numai dupa masurarea pe teren a traseului.

Lungimea cablului include si pe aceea necesara pozarii sinuoase a acestuia.

Contract nr/Contract no.	Nr. document/Document no.	Rev/Rev	Specialitate doc./Specialty doc.
1637.3/2017	1637.3-A-0008.17	0	AUTOMATIZARE